

OFFICE OF THE ASST ENGINEER
MANDAL PARISHAD GHATKESAR
RANGA REDDY DISTRICT

Date: 06-04-2016

STRUCTURAL SOUNDNESS CERTIFICATE

This is to certify that the construction of building H. No. 2-96 at Sy. No. 757/A/2 Situated at Chowdaryguda (Gramapanchayathi & Village), Ghatkesar (Mandal), Ranga Reddy (Dist), Telangana (State).

Belongs to;


Sri M. Vijayasimha Reddy and Sri M. Surender Reddy both sons of Sri M. Bal Reddy, residents of H.No. 16-11-302/3, Moosarambagh, Hyderabad – 500036.

The existing structure has been analyzed as a space frame and designed as per Indian Standard Codes of practice i.e. IS:456-2000 using the fundamentals of Limit State Design. Loads are considered as per IS:875 (I to V) and IS:1893-2002 (I).

Safe bearing capacity (SBC) of soil is considered as 30 tonnes / Sq. mtrs

Total built-up area (Ground + 2 floors):17,681 sft. or 1643 Sq. Mts.

The age of the Building is 10 yrs. The expected future life of the Building is 60 Years.


8/4/2016
ASSISTANT ENGINEER (PRI)
Mandal Parishad, Ghatkesar,
R.R.Dist. (T.S)


PRINCIPAL
ROTTERDAM SCHOOL
Chowdaryguda (V), Ghatkesar (M),
Medchal Dist, Telangana - 500088
Affiliation No. 3630186

**OFFICE OF THE ASST ENGINEER
MANDAL PARISHAD GHATKESAR
RANGA REDDY DISTRICT**

Date: 06-04-2016

STRUCTURAL SOUNDNESS CERTIFICATE

This is to certify that the construction of building H. No. 2-97 at Sy. No. 7571A/2
Situating at Chowdaryguda (Gramapanchayathi & Village), Ghatkesar (Mandal), Ranga
Reddy (Dist), Telangana (State).

Belongs to;

Sri M. Vijayasimha Reddy and Sri M. Surender Reddy both sons of Sri M. Bal Reddy,
residents of H. No. 16-11-302/3, Moosarambagh, Hyderabad - 500036.

The existing structure has been analyzed as a space frame and designed as per
Indian Standard Codes of practice i.e. IS:456-2000 using the fundamentals of Limit
State Design. Loads are considered as per IS:875 (I to V) and IS:1893-2002 (I)s.

Safe bearing capacity (SBC) of soil is considered as 30 tonnes / Sq. Mtrs

Total built-up area (Ground + 2 floors):17,681 Sft. or 1643 Sq. Mtrs.

The age of the Building is 10 yrs. The expected future life of the Building is 60 Years.



24/2016
ASSISTANT ENGINEER (PRI)
Mandal Parishad, Ghatkesar,
R.R.Dist. (T.S)



PRINCIPAL
ROTTERDAM SCHOOL
Chowdaryguda (V), Ghatkesar (M),
Medchal Dist, Telangana - 500038
Affiliation No. 3630186